



Town of Algoma
 15 N. Oakwood Road
 Oshkosh, WI 54904
 Phone: 920.235-3789

STORMWATER MANAGEMENT SYSTEM INSPECTION, OPERATION, & MAINTENANCE FORM

Site or Subdivision Name:		Parcel ID:		
Site Address / Location:				
Inspection Frequency (check one): <input type="checkbox"/> > 0.5 Inch Rain (R) <input type="checkbox"/> Monthly (M) <input type="checkbox"/> Biannual (B) <input type="checkbox"/> Annual (A) <input type="checkbox"/> 5-Year Cycle (C) <input type="checkbox"/> Other				
Date of Inspection:		Inspector Name:		Maintenance Crew Leader Name:
Maintenance Items – Wet or Dry Detention Pond (1001)	Frequency	Observed?	Inspector Comments	Maintenance Completed
1. Debris & Litter – At inlets and outlets (grate, orifice, weir, pipe, spillway, etc.)	R,M,B,A,C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
2. Debris & Litter – At other device locations (open water, shoreline, vegetation)	A,C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
3. Vegetation – Vegetation health or density concern (water, disease, etc.)	M,B,A,C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
4. Vegetation – Noxious weed or tree root concern (unauthorized planting, etc.)	A,C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
5. Wildlife – Burrow holes, fish damage, animal paths, or other concern	A,C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
6. Erosion – Channel, rill, scour, shoreline, or other erosion concern	A,C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
7. Structural inlet or outlet concern (crack, spalling, corrosion, pipe joint, etc.)	A,C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
8. Structural liner concern (burrow hole, tree/shrub root, erosion, leak, etc.)	A,C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
9. Structural embankment concern (seeping, settling, slumping, roots, etc.)	R,M,B,A,C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
10. Structural spillway concern (dimensions, freeboard, unstable, leaking, etc.)	R,M,B,A,C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
11. Backflow preventor or flap gate concern (clogged, missing, etc.)	R,M,B,A,C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
12. Aerator or fountain system operational concern	R,M,B,A,C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
13. If < 10,000 feet from airport, bird deterrent concern (large bird, etc.)	M,B,A,C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
14. Wet Pond – Sediment accumulation concern (PP water depth < 3.5 feet)	C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
15. Dry Pond – Sediment accumulation concern (storage reduced by > 10%)	C	<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes
16. Other (graffiti, illicit discharge, illegal dumping, etc.):		<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes